



**PRE BID
ADDENDUM NO. 5**

TO THE BID DOCUMENTS

FOR

CONEJO VALLEY UNIFIED SCHOOL DISTRICT

AT

Newbury Park High School
Softball Field and Parking Lot

PROJECT # MP19/20-16-NPH

PREPARED BY

Name – Ken Thomas

July 23, 2020

NOTICE TO BIDDERS: You are hereby notified of the following changes, clarifications or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and subsequent Addenda. This addendum shall supersede the original contract documents, and any previous addenda wherein it contradicts the same and shall take precedence over anything to the contrary therein. All other conditions remain unchanged. The bidders shall acknowledge receipt of this Addendum in the Bid Form, Specification Section 00 21 00.

This Addendum consists of 3 pages:

ADDENDUM NO. 5

Project # MP19/20-16-NPH
Page - 1 OF 3

Changes to the Project Plans/Specifications:

<u>ITEM</u>	<u>SHEET/SECTION</u>	<u>DESCRIPTION</u>
-------------	----------------------	--------------------

RFI QUESTIONS / ANSWERS

1. Reference to sheet L1.00, please clarify with the followings:
There are symbols labeled MV, PR, & FS at irrigation point of connection. However these are not identified on the irrigation materials legend. Please advise.

ANSWER: Omit symbols labeled MV, PR, & FS; not used.
2. Irrigation materials legend provides model of backflow preventer but this is not shown on the plans, please confirm that there is no backflow preventer for this project.

ANSWER: Correct, there is no backflow preventer for the current project as one already exists upstream from the project point-of-connection, maintained by the district. Omit detail F “backflow preventer”, sheet L2.00.
3. Irrigation note #1 requires to run 2" conduit from valves A1, A2, & A3 to end of mainline at service road but the plan shows valves A1 & A2 only. Please advise.

ANSWER: Valve A3 has been omitted; 2” conduit to valves A1 and A2 only.
4. There is no irrigation shown to be installed for the 2 proposed trees, please advise.

ANSWER: Tree bubblers were omitted at the request of district maintenance. Trees will be irrigated by flood bubblers.
5. Reference to sheet L3.00, the infield mix was called out at entire baseball field areas. However, sheet A1.02 shows turf between the bases and Pitcher's mound area. Please advise.

ANSWER: Turf between bases and pitcher’s mound were omitted at the request of district maintenance. Sheet A1.02 should be updated to reflect infield mix in this area
6. On Page 5 of 8 in the PB Pre-Bid Walk Agenda, Bid Package #4 lists Tree Well Grates. There does not appear to be a spec or detail on them. Would you please provide information on the tree grates and quantities you intend to include in this scope?

ANSWER: Remove any reference to them. Tree Grates have been removed from the scope of work.

ADDENDUM NO. 5

7. On Plan Page L3.00, it references “future volleyball courts and to install turf there. On Plan Sheet A1.00 it references sand @ volleyball courts. I cannot find the spec for the sand.

ANSWER: All references to sand volleyball courts and sand have been removed from this project. Disregard any reference to sand on legend.

8. **Clarification on Bid Package # 4.** Spec Sections included in this Bid Package are the following only: **02 07 20, 02 22 25, 02 81 0, 02 88 00 and 02 90 00.** All others listed in the Summary of Work for Bid Package #4 are included in other Bid Packages. Please review Addendum #2 as well for additional clarifications.

6. **General Note:** Per Addendum No. 2 – New Landscape Spec Section 00 29 00 Item # 1.01G, Include in the Landscape Bid Package Bid Form ALT #1 – Cost for Sod Turf in Lieu of Hydro-Seed Turf.

7. **General Note:** Cut-Off date for RFI’s has been met. All RFI’s submitted after this Addendum, will not be included as part of this project.

End of Addendum No. 5

Please acknowledge receipt of this **Addendum No. 5** by return e-mail to:

Mike Stanford – mikestanford@conejousd.org

Acknowledge this and all Addenda with your bid package on the Bid Form.

ADDENDUM NO. 5 TO THE BID DOCUMENTS FOR Softball and Parking Lot Project MP19/20-16-NPH	
<u>ACKNOWLEDGEMENT:</u>	
_____	_____
Signature	Date
_____	_____
Name (Print or Type)	Company Name

ADDENDUM NO. 5