



**PRE-BID ADDENDUM NO. 001 – Str Concrete**

TO THE BID DOCUMENTS

FOR THE

**Westlake High School**  
New STEM Building

AT

CONEJO VALLEY UNIFIED SCHOOL DISTRICT

**Project # MP18/19-72-WHS**

PREPARED BY

Ken Thomas

June 24, 2020

**NOTICE TO BIDDERS:** You are hereby notified of the following changes, clarifications or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and subsequent Addenda. This addendum shall supersede the original contract documents, and any previous addenda wherein it contradicts the same and shall take precedence over anything to the contrary therein. All other conditions remain unchanged. The bidders shall acknowledge receipt of this Addendum in the Bid Form, Specification Section 00 21 00.

This Addendum consists of   2   pages:

**Changes to the Project Manual/Specifications:**

<u>ITEM</u>	<u>SECTION</u>	<u>DESCRIPTION</u>
1.	General	For Clarification, the Structural Concrete contractor will be responsible to back-fill and compact his footings back to finish grade upon completion of his/hers scope of work. Compaction will be 90%.

Please acknowledge receipt of this **Addendum No. 001** by return email to:

Ken Thomas – kthomas@conejousd.org

**Acknowledge this and all Addenda with your bid package on the Bid Form.**

<b>ADDENDUM NO. 001</b>	
<b>TO THE BID DOCUMENTS FOR</b>	
WHS STEM Building – Project # MP18/19-72 WHS	
<b><u>ACKNOWLEDGEMENT:</u></b>	
_____	_____
Signature	Date
_____	_____
Name (Print or Type)	Company Name